

GENERATOR 375 KVA 3-PH. 60 CYCLES
240 VOLTS 400 R.P.M. WESTINGHOUSE

WOODWARD 5000 F.T.B.
ROTARY PUMP
MOTOR DRIVEN

TYPE H-3 WOODWARD OIL
PRESSURE GOVERNOR

EXCITER

PRESENT FLOOR

SEE PLAN VIEW

PENSTOCK
FLOW
7' 2" AGE

7'-1"

WATER LINE

BOTTOM WHEEL PIT

MOTOR DRIVEN PUMP

ARCH

ARCH

MOVEMENT AS

OPEN

CLOSED

GOVERNOR

18" MANHOLE

20'x7'x25' I BEAM 12'-0" LONG

PASSAGE

PLAN VIEW

NEW PIER

20'x7'x85' I BEAMS 5'-11" LONG

20'x7'x85' I BEAM 20'-0" LONG

REPAIRS
R-116280