



PHASE UNDERVOLTAGE 27 59/59I PHASE OVERVOLTAGE
GROUND UNDERVOLTAGE 27G 59G GROUND OVERVOLTAGE
DIRECTIONAL POWER 32 60FL FUSE LOSS
LOSS OF FIELD 40 81 OVER/UNDER FREQUENCY
CURRENT UNBALANCE 46 OSC TRIGGER
VOLTAGE UNBALANCE 47 DIAGNOSTIC
OVERCURRENT 51N/51V RELAY OK
OUTPUT 1 OUTPUT 2

M-3410A
INERTIE / GENERATOR
PROTECTION

Integrated Protection Systems®

TARGET/OUTPUT
RESET

BECKWITH
ELECTRIC CO. INC.
Made in U.S.A.



CB1 TURBINE
CIRCUIT BREAKER

86 RELAY

CB2 CAPACITOR
CIRCUIT BREAKER

